

Rentals

miltoncat.com

MPS1000

Wilton CAT

WEISPERWATT

MQ POWER

Milton CAT

125

DANGER
HIGH VOLTAGE



DIESEL POWERED AC GENERATOR

MODEL **DCA-125SSJU4i**

SERIAL NO. **7501193**

AC GENERATOR

MODEL **DB-1381J3**

ARMATURE CONNECTION

Star with Neutral **Zigzag**

PHASE **3** **Single**

FREQUENCY **60 Hz** **60 Hz**

RATED OUTPUT **125kVA(100kW)** **72kW(72kVA)**

RATED VOLTAGE **240v** **480v** **240v** **120v**

RATED CURRENT **301 A** **150 A** **301 A**

POWER FACTOR **0.8** **1.0**

Class F Insulation System

ENGINE

MODEL **John Deere 4045HFG93**

TYPE **4 CYL. 4 CYCLE**

RATED SPEED **1800 RPM**

DISPLACEMENT **4.5L**

FUEL TANK CAP. **169 GAL**

CIRCUIT BREAKER



3 PHASE

DECREASE INCREASE
VOLTAGE REGULATOR



PHASE SELECTOR SWITCH MUST BE IN W-U POSITION DURING 240/120V SINGLE PHASE OPERATION

MQ POWER
WHISPERWATT
125 kVA AC GENERATOR

M35100000

PANEL LIGHT SWITCH

FUEL LEAK DETECTED

ON

OFF



ECU Series 800 Controller

Engine Started ●
Shutdown ●
Pre-Alarm ●

Buttons: Acknowledge, Change, Option, Program, Exit

AUTO MANUAL
OFF/RESET

● HOUR CHECK BUTTON

SAFETY INSTRUCTIONS

Improper operation of this machine can cause severe injury or death.

- Read the instruction manual carefully before operating or servicing.
- The machine should only be operated by a person with sufficient knowledge and skill to operate safe operation.
- High voltage circuits are located inside the engine terminal cover and control panel.
- Close the cover and control panel before operating.
- Warning parts and hot surfaces are contained within the enclosure.
- Close all doors and lock them before operating.

M35100000



WARNING

ELECTRIC SHOCK HAZARD

Do not touch internal wiring or components while the machine is operating.

Turn power off before servicing.